

License No. 129 Date SEPT, 19

WATER WELL REPORT

STATE OF WASHINGTON

Application No.

Permit No.

(1) OWNER: Name J. T. BONNER Address 4465 N. MURRAN RD. OAK HARBOUR
 (2) LOCATION OF WELL: County ISLAND SE 1/4 SE 1/4 Sec. 3 T. 33 N. R. 1E W.M.
 Bearing and distance from section or subdivision corner

(3) PROPOSED USE: Domestic ☒ Industrial ☐ Municipal ☐
 Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) _____
 New well ☒ Method: Dug ☐ Bored ☐
 Deepened ☐ Cable ☒ Driven ☐
 Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
 Drilled 17 ft. Depth of completed well 17 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6 " Diam. from 0 ft. to 113 ft.
 Threaded ☐ " Diam. from _____ ft. to _____ ft.
 Welded ☒ " Diam. from _____ ft. to _____ ft.

Perforations: Yes ☐ No ☒

Type of perforator used _____
 SIZE of perforations _____ in. by _____ in.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

Screens: Yes ☒ No ☐

Manufacturer's Name Johnson
 Type STAINLESS Model No. _____
 Diam. 5 Slot size 14 from 113 ft. to 117 ft.
 Diam. _____ Slot size _____ from _____ ft. to _____ ft.

Gravel packed: Yes ☐ No ☒ Size of gravel. _____
 Gravel placed from _____ ft. to _____ ft.

Surface seal: Yes ☒ No ☐ To what depth? 18+ ft.
 Material used in seal BENTON
 Did any strata contain unusable water? Yes ☐ No ☒
 Type of water? _____ Depth of strata _____
 Method of sealing strata off _____

(7) PUMP: Manufacturer's Name _____
 Type: Sub HP.

(8) WATER LEVELS: Land-surface elevation 30 ft.
 Static level 15' ft. below top of well Date Sept 85
 Artesian pressure _____ lbs. per square inch Date _____
 Artesian water is controlled by _____ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☐ No ☒ If yes, by whom? _____
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.

" " " " " "
 " " " " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

| Time | Water Level | Time | Water Level | Time | Water Level |
|------|-------------|------|-------------|------|-------------|
| | | | | | |
| | | | | | |
| | | | | | |

Date of test _____
 Bailer test 10 gal./min. with _____ ft. drawdown after 4 hrs.

Artesian flow _____ g.p.m. Date _____

Temperature of water _____ Was a chemical analysis made? Yes ☐ No ☒

(10) WELL LOG:

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

| MATERIAL | FROM | TO |
|----------------------------|------|-----|
| SANDY CLAY | 2 | 70 |
| HARD COMPACT GRAVELLY CLAY | 70 | 113 |
| WATER GRAVEL | 113 | 117 |

12 G.P.M. MAX

Work started _____, 19____ Completed SEPT 85, 19____

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WHIRLEY DRILLERS
 (Person, firm, or corporation) (Type or print)

Address OAK HARBOUR WA

[Signed] Dennis Folan
 (Well Driller)

License No. 129 Date SEPT 85, 19____